

Viral Filtration Efficiency (VFE) Final Report

Test Article: AntiVirus - Respilon
 Laboratory Number: 754320
 Study Received Date: 05 May 2014
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0007 Rev 09

Summary: The VFE test is performed to determine the filtration efficiency by comparing the viral control counts to test article effluent counts. A suspension of bacteriophage Φ X174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. This method allows a reproducible challenge to be delivered to the test articles. The VFE test procedure was adapted from ASTM F2101. All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Sponsor Labeled Side
 Area Tested: ~45.6 cm²
 VFE Flow Rate: 28.3 Liters per minute (L/min)

Results:

Test Article Number	Percent VFE (%)
1	99.9
2	99.9
3	99.9
4	99.9
5	99.9

Note: Plate count totals for each stage are available upon request.

Mean Positive Control Count: 2,082 plaque forming units (PFU)
 Negative Monitor Count: <1 PFU
 Mean Particle Size (MPS): 2.8 μ m



Study Director

Sarah Smit, B.S.

22 May 2014
 Study Completion Date